

Príloha č.2

Parametre vykurovacej sústavy

$$V_{\text{system}} : 1600 \text{ l}$$

P_0 : 1.00 bar

P_{otv}	:	3,00 bar
-----------	---	----------

P_e : 2.7 bar

$$(T)_{\max} : 110^{\circ}\text{C}$$

e	:	5.03 %
---	---	--------

3,000

Vwr : 8,0 l

min : 8,0 l

Vwr : 8,0 l

$$V_e = 80,48 \text{ l}$$

$$V_e = 80,48 \text{ l}$$

$$V_{\text{exp.min}} = 192,57 \text{ l}$$

$$V_{\text{exp.min}} = 192,57 \text{ l}$$

$$V_n = 300,00 \text{ l}$$

P_{a.min} >= 1,0548 bar

P_{a.min} >= 1,0548 bar

P_{a,max} <= 1,4728 bar

P_{a,max} <= 1,4728 bar

01

300/6.0

300 I

d600 x 1330mm

100 kPa

1 ks

300 I

Celkový expanzný objem