

Príloha č.1 - Súpis jestvujúcich a navrhovaných svetelných zdrojov

Č.M.	NÁZOV MIESTNOSTI	JESTVUJÚCI STAV				NAVRHOVANÉ RIEŠENIE				POZNÁMKA
		SVIETIDLO	VÝKON SV. (W)	PRÍKON SV. (W)	Ppc	SVIETIDLO	VÝKON SV. (W)	PRÍKON SV. (W)	Ppc	
0.0	Vonkašie priestory	3x E27 60W	180,0	180,0	0,0	3x G23 2x9W, ECG	54,0	60,0	6,0	
		T8 2x36W, CCG	72,0	90,0	18,0	T8 2x36W, ECG	72,0	78,0	6,0	
0.01	Sklad	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
0.02	Umyváreň	E27 60W	60,0	60,0	0,0	G23 2x9W, ECG	18,0	20,0	2,0	
0.03	Sklad	4x T8 2x36W, CCG	288,0	360,0	72,0	4x T8 2x36W, ECG	288,0	312,0	24,0	
0.04	Sklad	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
0.05	Sklad	4x T8 2x36W, CCG	288,0	360,0	72,0	4x T8 2x36W, ECG	288,0	312,0	24,0	
0.06	Chodba	2x T8 2x36W, CCG	144,0	180,0	36,0	T8 1x36W, ECG	36,0	39,0	3,0	
						G23 2x9W, ECG	18,0	20,0	2,0	
0.07	Sklad	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
0.08	Predsieň	T8 2x36W, CCG	72,0	90,0	18,0	G23 2x9W, ECG	18,0	20,0	2,0	
0.09	WC	E27 60W	60,0	60,0	0,0	G23 2x9W, ECG	18,0	20,0	2,0	
0.10	WC	E27 60W	60,0	60,0	0,0	G23 2x9W, ECG	18,0	20,0	2,0	
0.11	Chodba	T8 2x36W, CCG	72,0	90,0	18,0	T8 2x36W, ECG	72,0	78,0	6,0	
0.12	Schodisko	3x E27 60W	180,0	180,0	0,0	3x G23 2x9W, ECG	54,0	60,0	6,0	
0.13	Sklad	2x E27 60W	120,0	120,0	0,0	2x E27 LED 5W	10,0	10,0	0,0	len zmena zdroja
0.13.1	Sklad	4x E27 60W	240,0	240,0	0,0	4x E27 LED 5W	20,0	20,0	0,0	len zmena zdroja
0.14	Sklad	T8 2x36W, CCG	72,0	90,0	18,0	T8 1x36W, ECG	36,0	39,0	3,0	
0.15	Sklad	2x E27 60W	120,0	120,0	0,0	2x E27 LED 2x6W	24,0	24,0	0,0	len zmena zdroja
		3x E27 40W	120,0	120,0	0,0	3x E27 LED 5W	15,0	15,0	0,0	len zmena zdroja
0.17	Sklad	5x T8 2x36W, CCG	360,0	450,0	90,0	5x T8 2x36W, ECG	360,0	390,0	30,0	
0.18	Sklad	6x E27 40W	240,0	240,0	0,0	6x E27 LED 5W	30,0	30,0	0,0	len zmena zdroja
0.19	Sklad	E27 60W	60,0	60,0	0,0	G23 2x9W, ECG	18,0	20,0	2,0	
0.20	Regul. Miestnosť pl.	E27 100W	100,0	100,0	0,0	T8 2x36W, ECG	72,0	78,0	6,0	v "Ex" vyhotovení
0.23	Sklad	3x T8 2x36W, CCG	216,0	270,0	54,0	4x T8 2x36W, ECG	288,0	312,0	24,0	
		E27 60W	60,0	60,0	0,0					
0.24	Sklad	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
0.25	Sklad	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
0.26	Garáž	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	

0.27 Obsluha kotlov	3x T8 2x36W, CCG	216,0	270,0	54,0	3x T8 2x36W, ECG	216,0	234,0	18,0
0.28 Upratovačka	T8 2x36W, CCG	72,0	90,0	18,0	T8 2x36W, ECG	72,0	78,0	6,0
	2x E27 60W	120,0	120,0	0,0	2x G23 2x9W, ECG	54,0	60,0	6,0
0.29 Umyváreň	T8 2x36W, CCG	72,0	90,0	18,0	T8 2x36W, ECG	72,0	78,0	6,0
0.30 Soc. Miestnosť	E27 100W	100,0	100,0	0,0	T8 1x36W, ECG	36,0	39,0	3,0
0.31 Predsieň	2x T8 2x36W, CCG	144,0	180,0	36,0	2x G23 2x9W, ECG	36,0	40,0	4,0
0.32 Chodba	5x T8 2x36W, CCG	360,0	450,0	90,0	4x T8 1x36W, ECG	144,0	156,0	12,0
0.33 Miestnosť	2x E27 60W	120,0	120,0	0,0	2x G23 2x9W, ECG	18,0	20,0	2,0
0.34 Miestnosť	2x E27 60W	120,0	120,0	0,0	2x G23 2x9W, ECG	18,0	20,0	2,0
0.35 Miestnosť	2x E27 60W	120,0	120,0	0,0	2x G23 2x9W, ECG	18,0	20,0	2,0
0.36 Kotelňa	6x T8 2x36W, CCG	432,0	540,0	108,0	6x T8 2x36W, ECG	432,0	468,0	36,0
0.37 Chodba	T8 2x36W, CCG	72,0	90,0	18,0	T8 1x36W, ECG	36,0	39,0	3,0
0.38 Sklad	4x T8 2x36W, CCG	288,0	360,0	72,0	4x T8 2x36W, ECG	288,0	312,0	24,0
0.39 Schodisko	T8 2x36W, CCG	72,0	90,0	18,0	T8 2x36W, ECG	72,0	78,0	6,0
		7400,0	1044,0			4555,0	352,0	

1.01 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
1.02 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
1.03 Chodba	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 1x36W, ECG	72,0	78,0	6,0	
1.04 Kancelária	4x T8 2x36W, CCG	288,0	360,0	72,0	4x T8 2x36W, ECG	288,0	312,0	24,0	
1.05 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
1.06 Kancelária	4x T8 2x36W, CCG	288,0	360,0	72,0	4x T8 2x36W, ECG	288,0	312,0	24,0	
1.07 Sklad	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
1.08 Hala	15x T8 4x18W, CCG	1080,0	1350,0	270,0	15x T8 4x18W, ECG	1080,0	1170,0	90,0	vstavané
	2x PL-C 18W	36,0	40,0	4,0	2x PL-C 18W	36,0	40,0	4,0	bez zmeny
	6x HAL GU10 20W	120,0	120,0	0,0	6x LED GU10 5W	30,0	30,0	0,0	len zmena zdroja
1.09 Terasa	E27 60W	60,0	60,0	0,0	G23 2x9W, ECG	18,0	20,0	2,0	
1.10 Schodisko	T8 2x36W, CCG	72,0	90,0	18,0	3x G23 2x9W, ECG	54,0	60,0	6,0	
	2x E27 60W	120,0	120,0	0,0					
1.11 Telef. ústredňa	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
1.12 Kancelária	6x T8 2x36W, CCG	432,0	540,0	108,0	6x T8 2x36W, ECG	432,0	468,0	36,0	
1.13 Kancelária	4x T8 2x36W, CCG	288,0	360,0	72,0	4x T8 2x36W, ECG	288,0	312,0	24,0	
1.14 Hl. rozvádzač	T8 4x36W, CCG	144,0	180,0	36,0	T8 2x36W, ECG	72,0	78,0	6,0	
1.15 Schodisko	T8 4x18W, CCG	72,0	90,0	18,0	T8 4x18W, ECG	72,0	78,0	6,0	vstavané

	E27 60W	60,0	60,0	0,0	G23 2x9W, ECG	18,0	20,0	2,0	
1.16 Stála služba	4x T8 4x36W, CCG	576,0	720,0	144,0	4x T8 4x36W, ECG	576,0	624,0	48,0	
1.17 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
1.18 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
1.19 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
1.20 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
1.21 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
1.22 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
1.23 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
1.24 Rozmnožovňa	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
1.25 Fotokomora	T8 2x36W, CCG	72,0	90,0	18,0	T8 2x36W, ECG	72,0	78,0	6,0	
1.26 Chodba	6x T8 2x36W, CCG	432,0	540,0	108,0	8x T8 1x36W, ECG	288,0	312,0	24,0	
1.27 Umyváreň	E27 60W	60,0	60,0	0,0	G23 2x9W, ECG	18,0	20,0	2,0	
1.28 Umyváreň	E27 60W	60,0	60,0	0,0	G23 2x9W, ECG	18,0	20,0	2,0	
1.29 Soc. Miestnosť	4x E27 60W	240,0	240,0	0,0	G23 2x9W, ECG	18,0	20,0	2,0	
1.30 WC	-	0,0	0,0	0,0	-	0,0	0,0	0,0	
1.31 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
1.32 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
1.33 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
1.34 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
1.35 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
1.36 Schodisko	3x E27 60W	180,0	180,0	0,0	G23 2x9W, ECG	18,0	20,0	2,0	
1.37 Schodisko	3x T8 4x18W, CCG	216,0	270,0	54,0	3x T8 4x18W, ECG	216,0	234,0	18,0	vstavané
1.38 Predaj kolkov	2x T8 4x18W, CCG	144,0	180,0	36,0	2x T8 4x18W, ECG	144,0	156,0	12,0	
1.39 WC muži	3x E27 60W	180,0	180,0	0,0	3x G23 2x9W, ECG	54,0	60,0	6,0	
1.40 WC ženy	T8 4x18W, CCG	72,0	90,0	18,0	G23 2x9W, ECG	18,0	20,0	2,0	
1.41 Sklad	E27 60W	60,0	60,0	0,0	G23 2x9W, ECG	18,0	20,0	2,0	
			9820,0	1732,0			7370,0	572,0	
2.01 Kancelária	6x T8 2x36W, CCG	432,0	540,0	108,0	6x T8 2x36W, ECG	432,0	468,0	36,0	
2.02 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0	
2.03 Chodba	3x T8 2x36W, CCG	216,0	270,0	54,0	3x T8 1x36W, ECG	108,0	117,0	9,0	
2.04 Chodba	E27 60W	60,0	60,0	0,0	G23 2x9W, ECG	18,0	20,0	2,0	
2.05 Sklad	T8 2x36W, CCG	72,0	90,0	18,0	T8 2x36W, ECG	72,0	78,0	6,0	

2.06 Kancelária	4x T8 2x36W, CCG	288,0	360,0	72,0	4x T8 2x36W, ECG	288,0	312,0	24,0
2.10 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0
2.11 Terasa	-	0,0	0,0	0,0	-	0,0	0,0	0,0
2.12 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0
2.13 Predsieň	T8 2x36W, CCG	72,0	90,0	18,0	T8 1x36W, ECG	36,0	39,0	3,0
2.14 Schodisko	T8 2x36W, CCG	72,0	90,0	18,0	G23 2x9W, ECG	18,0	20,0	2,0
2.15 Kancelária	4x T8 2x36W, CCG	288,0	360,0	72,0	4x T8 2x36W, ECG	288,0	312,0	24,0
2.16 Kancelária	4x T8 2x36W, CCG	288,0	360,0	72,0	3x T8 2x36W, ECG	216,0	234,0	18,0
2.17 Izba	T8 2x36W, CCG	72,0	90,0	18,0	T8 2x36W, ECG	72,0	78,0	6,0
2.18 Sklad	2x T8 3x36W, CCG	216,0	270,0	54,0	2x T8 2x36W, ECG	144,0	156,0	12,0
2.19 Kuchynka	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0
2.20 Umyváreň	T8 2x36W, CCG	72,0	90,0	18,0	T8 1x36W, ECG	36,0	39,0	3,0
2.21 WC	E27 60W	60,0	60,0	0,0	G23 2x9W, ECG	18,0	20,0	2,0
2.22 WC	E27 60W	60,0	60,0	0,0	G23 2x9W, ECG	18,0	20,0	2,0
2.23 Schodisko	6x E27 60W	360,0	360,0	0,0	2x G23 2x9W, ECG	36,0	40,0	4,0
2.24 Kancelária	4x T8 2x36W, CCG	288,0	360,0	72,0	4x T8 2x36W, ECG	288,0	312,0	24,0
2.25 Kancelária	2x T8 4x36W, CCG	288,0	360,0	72,0	2x T8 2x36W, ECG	144,0	156,0	12,0
2.26 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0
2.27 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0
2.28 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0
2.29 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0
2.30 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0
2.31 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0
2.32 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0
2.33 Sklad	T8 2x36W, CCG	72,0	90,0	18,0	G23 2x9W, ECG	18,0	20,0	2,0
2.34 WC muži predsieň	E27 60W	60,0	60,0	0,0	G23 2x9W, ECG	18,0	20,0	2,0
2.35 WC ženy predsieň	E27 60W	60,0	60,0	0,0	G23 2x9W, ECG	18,0	20,0	2,0
2.36 WC muži	4x E27 60W	240,0	240,0	0,0	T8 1x36W, ECG	36,0	39,0	3,0
2.37 WC kabínky	-	0,0	0,0	0,0	-	0,0	0,0	0,0
2.38 Kancelária	4x T8 2x36W, CCG	288,0	360,0	72,0	4x T8 2x36W, ECG	288,0	312,0	24,0
2.39 Kancelária	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 2x36W, ECG	144,0	156,0	12,0
2.40 Kancelária	4x T8 2x36W, CCG	288,0	360,0	72,0	4x T8 2x36W, ECG	288,0	312,0	24,0
2.41 Chodba	6x T8 2x36W, CCG	432,0	540,0	108,0	8x T8 1x36W, ECG	288,0	312,0	24,0
	T8 4x36W, CCG	144,0	180,0	36,0				

2.42 Terasa	2x E27 60W	120,0	120,0	0,0	2x G23 2x9W, ECG	36,0	40,0	4,0
2.43 Chodba	2x T8 2x36W, CCG	144,0	180,0	36,0	3x T8 1x36W, ECG	108,0	117,0	9,0
			8220,0	1440,0			5485,0	427,0
3.01 WC muži	3x E27 60W	180,0	180,0	0,0	T8 1x36W, ECG	36,0	39,0	3,0
3.02 WC kabínka muži	-	0,0	0,0	0,0	-	0,0	0,0	0,0
3.03 Predsieň muži	E27 60W	60,0	60,0	0,0	G23 2x9W, ECG	18,0	20,0	2,0
3.04 Predsieň WC ženy	E27 60W	60,0	60,0	0,0	G23 2x9W, ECG	18,0	20,0	2,0
3.05 Chodba	T8 2x36W, CCG	72,0	90,0	18,0	3x T8 1x36W, ECG	108,0	117,0	9,0
3.06 Šatňa	2x T8 2x36W, CCG	144,0	180,0	36,0	2x T8 1x36W, ECG	108,0	117,0	9,0
3.07 Kuchynka	E27 60W	60,0	60,0	0,0	T8 1x36W, ECG	36,0	39,0	3,0
3.08 Zasadacia miestnosť	8x T8 4x36W, CCG	1152,0	1440,0	288,0	8x T8 4x36W, ECG	1152,0	1248,0	96,0
	2x E27 60W	120,0	120,0	0,0	2x G23 2x9W, ECG	36,0	40,0	4,0
3.09 Schodisko	6x E27 60W	360,0	360,0	0,0	T8 2x36W, ECG	72,0	78,0	6,0
			2550,0	342,0			1718,0	134,0

JESTVUJÚCI STAV: **27990,0 W**

NAVRHOVANÝ STAV: **19128,0 W**

Ppc **4558,0 W**

Ppc **1485,0 W**

Ppc - Celkový inštalovaný pasívny príkon riadiacej sústavy vo svetidle